

ADDENDUM 2: RESPONSES TO QUESTIONS
RFP #10-2013-CASU - Audio System Upgrade

THE FOLLOWING QUESTIONS/CLARIFICATIONS WERE ASKED PRIOR TO THE 4/24 DEAD LINE. NOTWITHSTANDING ANY ANSWERS GIVEN VERBALLY AT THE WALK-THROUGH, ONLY THE FOLLOWING ANSWERS SHALL APPLY.

CLARIFICATIONS

- Assisted Listening Devices are not included in the criteria for this project.
- Court Reporter listening devices are not included in the criteria for this project but will remain a functional part of the system.
- Video standards should be based on HDMI and VGA.
- Telephone lines are not included in the criteria for this project.
- Wall jacks that do not have appliances currently affixed to them are not included in the criteria for this project.
- Ceiling microphones, where they exist, shall be ignored; they are not included in the criteria for this project.

PLEASE NOTE ADDENDUM 1 STILL STANDS AND SHOULD BE CONSIDERED – AS WELL AS ALL INFORMATION LISTED HERE – IN YOUR RESPONSE TO THIS SOLICITATION.

VENDOR QUESTIONS

Q. Is Extron equipment considered and (sic) equal replacement for the AMX equipment?

A. Yes – As long as it has the same or enhanced functions as AMX.

Q. Is the RFP asking for a minimum of 10 input channels and 9 output channels?

A. The RFP states no minimum or maximum, The Court is asking for the design to accomplish the needs required for each courtroom for fully functional and operational systems as identified in the criteria.

End of Addenda 4/28/14